

Evidence of performance

Burglar resistant characteristics

Test report 211 28260



Client **ELVIAL S.A.**
Aluminium Extrusion
P.O. Box 79

61100 Thessaloniki-Kilkis
Griechenland

Relevant standards and documents

DIN V ENV 1627 : 1999
Windows, doors, shutters –
Burglar resistance – Require-
ments and classification
DIN V ENV 1628 : 1999
DIN V ENV 1629 : 1999
DIN V ENV 1630 : 1999

Presentation



Product	Burglar resistant casement door assembly without fixed central mullion
Designation	Multi lock 5600
Exterior dimensions (W x H)	1400 mm x 2200 mm
(Frame) Material	Aluminium
Attack side	Lock side/Locking face according to DIN 107
Mode of operation	Double leaf, side-hung/side-and-bottom-hung
Glazing	DIN EN 356 Class P4
Hardware	Jet D, GU with 21 burglar resistant locks and lockable window handle F/Z RAL, GU
Installation	According to installation instructions by company ELVIAL S.A.
Special features	-/-

Instructions for use

The present summary serves to demonstrate the burglar resistant characteristics of building elements

Validity

The data and results given refer exclusively to the tested and described test specimen.

Testing for burglar resistance does not provide any information on any additional characteristics specific to the performance and quality of the construction submitted.

Notwithstanding the tested versions, the following dimensional changes are permitted:
width: +10% and -20%
height: +10% and -20%

Publishing notes

The ift document "Merkblatt „Bedingungen und Hinweise zur Benutzung von ift-Prüf-Dokumentationen“ (Conditions and guidance for the use of ift test documents) shall apply. The cover sheet can be used as abstract.

Contents

The evidence of performance comprises a total of 22 pages:

- 1 Item
 - 2 Procedure
 - 3 Individual results
 - 4 Evaluation
- Annex 1 (7 pages)
Annex 2 (3 pages)

Burglar resistance



Resistance class 2

ift Rosenheim
19 August 2004


Ulrich Sieberath
Director of Institute


pp. Christian Kehrer
Head Safety/Security Testing Windows, Doors



ift Rosenheim GmbH
Geschäftsführer:
Dipl.-Ing. (FH) Ulrich Sieberath
Dr. Jochen Peichl

Theodor-Gietl-Straße 7-9
D-83026 Rosenheim
Tel.+49 (0) 8031 / 261-0
Fax+49 (0) 8031 / 261-290
www.ift-rosenheim.de

Sitz: 83026 Rosenheim
AG Traunstein, HRB 14763
Sparkasse Rosenheim
Kto. 38 22
BLZ 711 500 00

Anerkannte Prüf-, Überwachungs-
und Zertifizierungsstelle
nach Landesbauordnung: BAY18
Notifizierung in Europa: Nr. 0757