

Classification Report

Number	18-000987-PR01 (NW-A01-02-en-01)
Owner	ELVIAL S.A. Aluminium Extrusion 25th Km national road Thessaloniki 61100 Kilkis Greece
Product	Tilt and turn window with fixed sublight
Designation	System: 8500-8600 Shipping name: Xclusive 85-86
Details	Manufacturer ELVIAL S.A., Aluminium Extrusion - Kilkis; Material Aluminium system with thermal break; Type of opening Tilt and turn; Opening direction DIN left, inward opening; Overall dimensions (W x H) 900 mm x 2300 mm
Special features	Additional sealing at all frame joints. Material compatibility must be taken into account. Material durability must be taken into account.

Result

Air permeability according to EN 12207:2016-12



Class: 4

Resistance to wind load according to EN 12210:2016-03



Class: C5/B5

Watertightness according to EN 12208:1999-11



Class: E1050

Basis *)

EN 14351-1:2006+A2:2016-09
*) and corresponding national versions
e.g. DIN EN)

Test report: 18-000987-PR01 PB-A01-02-en-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

ift Rosenheim
17.08.2018



Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing



Thomas Krichbaumer
Operating Testing Officer
Building Component Testing

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 028-527A5