

Evidence of Performance

Air permeability, Watertightness, Resistance to wind load, Operating forces



Test Report

NO. 11-001615-PR01

(PB-A01-0203-en-01)

Client	ELVIAL S.A. Aluminium Extrusion 26th km national road 61100 Santa-Kilkis Greece
Product	Lifting sliding casement door
Designation	System designation: Lift and slide EL6700
Performance-relevant product details	Material: Aluminium profiles with thermal break
Overall dimensions (WxH)	3,000 mm x 2,200 mm
Special features	Sealing additional sealed with pourable sealant

Basis

EN 14351-1:2006+A1:2010

Test standard/s:

EN 1026:2000-06

EN 1027:2000-06

EN 12046-1:2000-02

EN 12211:2000-06

Correspond/s to the national standard/s (e.g. DIN EN)

Representation



Instructions for use

The results obtained can be used by the manufacturer as the basis for the manufacturer ITT test report summary. Observe the specifications set out by the applicable product standard.

Validity

The data and results refer solely to the tested and described specimen. Classification remains valid as long as the product and the above basis remain unchanged. The results can be extrapolated under the manufacturer's own liability subject to observance of the relevant specifications set out by the applicable product standard. This test/evaluation does not allow any statement to be made on any further characteristics regarding performance and quality of the construction presented, in particular the effects of weathering and ageing were not taken into account.

Notes on publication

The ift-Guidance Sheet "Advertising with ift test documents" applies. The cover sheet can be used as an abstract.

The report contains a total of 28 pages.

Results

Air permeability according to EN 12207:1999-11



Class 4

Watertightness according to EN 12208:1999-11



Class 4A

Resistance to wind load according to EN 12210:1999-11/AC:2002-08



Class C2 / B2

Operating forces according to EN 13115:2001-07



Class 0

ift Rosenheim

28. October 2011


Robert Kolacny, Dipl.-Ing. (FH)
Deputy Head of Testing Department
Building Components


Peter Marquardt, Dipl.-Ing. (FH)
Operating Testing Officer
Tightness & Wind Load



ift Rosenheim GmbH

Geschäftsführer:
Dipl.-Ing. (FH) Ulrich Sieberath
Dr. Jochen Peichl

Theodor-Gietl-Str. 7 - 9
D-83026 Rosenheim
Tel.: +49 (0)8031/261-0
Fax: +49 (0)8031/261-290
www.ift-rosenheim.de

Sitz: 83026 Rosenheim
AG Traunstein, HRB 14763
Sparkasse Rosenheim
Kto. 3822
BLZ 711 500 00

Notified Body Nr.: 0757
Anerkannte PUZ-Stelle: BAY 18
 DAP-PL-0808 99
DAP-ZE-2298 00
TGA-ZM-16-93-00
TGA-ZM-16-93-60